

CERTIFICATE OF CONFORMANCE
EUROPEAN COMMUNITY
COUNCIL DIRECTIVE 89/336/EEC

Issued By: **RETLIF TESTING LABORATORIES**
795 Marconi Avenue
Ronkonkoma, NY 11779

Date of Issue: March 1998

Issued To: Napco Security Systems
333 Bayview Ave.
Amityville, NY 11801

Reference: Retlif Report Number R-7439-2

RETLIF TESTING LABORATORIES hereby acknowledges that compliance testing in accordance with the below listed standards was performed on a representative sample of the equipment listed below. RETLIF TESTING LABORATORIES further acknowledges that the test sample listed below was found to be in compliance with these standards. This certificate is hereby issued to the above named grantee and is valid only for the equipment identified below.

Manufacturer: Napco Security Systems

Equipment Tested: Alarm Control Panel with Two (2) Keypads

Model Numbers: Alarm Control Panel - GEM-P1632
Keypads - GEM-RP1CAE2 & GEM-RP2AS
Zone-Expansion Module - GEMEZM816

Brand Name: Napco

Product Type: Generic Light Industrial

- Note(s):
- 1) See attached report R-7439-2 for details and/or conditions pertaining to this certificate.
 - 2) Conforms to the emissions requirements of EN 50081-1:1992:
 - EN 55022:1994 Class B, Paragraph 4, Conducted Emissions, 150 kHz to 30MHz
 - EN 55022:1994 Class B, Paragraph 5, Radiated Emissions, 30MHz to 1GHz
 - 3) Conforms to the immunity requirements of EN 50082-1:1992:
 - IEC 801-2:1984 Electrostatic Discharge
 - IEC 801-3:1984 Radiated Immunity
 - IEC 801-4:1988 EFT, Power Leads
 - IEC 801-4:1988 EFT, I/O Leads